




Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332



If you order a full PU, you will receive our eco-friendly, sustainable cardboard blisters packed in a shelf-ready box. If you order a quantity smaller than a full PU, you will receive the eco-friendly, sustainable cardboard blisters without a shelf-ready box.

Please refer to the system description for the splicing connectors that can be used.

Your benefits:

- Easy, fast and safe to use
- · Can be used immediately and accessed again later
- Silicon-free
- Label-free
- Suitable for indefinite storage
- The complete system consisting of WAGO's gelboxes and splicing connectors has been VDE-tested and IPX8-certified.

Physical data	
Width	45.9 mm / 1.807 inches
Height	17.8 mm / 0.701 inches
Depth	33.6 mm / 1.323 inches

Mechanical data	
Design	Size 2
Mounting type	Flying leads
Protection type	IPX8
Suitable	für Verbindungsklemmen 4 mm²

Material data	
Note (material data)	Information on material specifications can be found here
Color	gray
Housing material	Polypropylene
Fire load	0 MJ
Weight	18.4 g
Weight	10.4 g

Environmental requirements	
Ambient temperature (operation)	-55 +85 ℃
Ambient temperature (storage)	0+40 °C

Commercial data	
ETIM 8.0	EC001170
ETIM 7.0	EC001170
PU (SPU)	48 (4) pcs
Country of origin	DE
GTIN	4055143998017
Customs tariff number	85389099990



Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332

Environmental Product Compliance

RoHS Compliance Status



Compliant,No Exemption

Approvals / Certificates

General approvals

rungsinstitut

VDE	
Approval	Standard
VDE VDE Prüf- und Zertifizie-	EN 60998

Certificate Name 400051938

Declarations of conformity and manufacturer's declarations

Approval	Standard	Certificate Name
EU-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-
UK-Declaration of Confor- mity WAGO GmbH & Co. KG	-	-

Downloads
Environmental Product Compliance
Compliance Search
Environmental Product Compliance 207-1332

Documentation

System Description			Bid Text		
System Description 207 Series Gel boxes	pdf 1156.45 KB	\downarrow	207-1332	xml 3.58 KB	\downarrow
System Description 207 Series Gel boxes	pdf 1191.37 KB	\downarrow	207-1331	docx 20.38 KB	\downarrow

CAD/CAE-Data	
CAD data	CAE data
2D/3D Models 207-1332	ZUKEN Portal 207-1332

Installation Notes

Installation



Open the Gelbox at the side latches.



Place the wired connector in the Gelbox.



Place the wired connector in the Gelbox.



Close the Gelbox.

Data Sheet | Item Number: 207-1332

https://www.wago.com/207-1332

Installation



Close latch securely.

- Re-accessible:
- Open the Gelbox.
- Remove the gel. Rewire with new components.
- nonno marnon compone







Lift the flap and pull the cover perforation forward.

Press in the perforation on the sides.

Tear off the cover from the perforation.



As a counter display: Bend the rear flap at the fold, straighten it and fix it in the cardboard cut-out



If the flap is not required, tear off from the perforation.



Subject to changes. Please also observe the further product documentation!